

# Edina Fire Department Responses - December 2014

### **Total Incidents = 479**

SITUATION	DATE	ADDRESS	PROPERTY USE	CAUSE
Structure Fire	12/10/14	3200 block of Galleria	Multi-family Dwelling	An arc from an electrical appliance ignited fumes from flammable paint thinner used in remodeling. Fire sprinkler head extinguished fire.
	12/25/14	4500 block of Garrison	Single Family Dwelling	Smoldering fire in wall cavity above fireplace fire box. Fireplace had been used all day long.
Assist Other Cities	12/6/14	4100 block of Terrace La	House/Minnetonka	Assist with extinguishment.
	12/12/14	1000 block of 11th Ave S	Multi-family/Hopkins	Standby at scene.
	1 Mutual Aid call was cancelled en route by St Louis Park Fire Department			
		1 Mutual Aid call was cancelled	d en route by Eden Prairie	Fire Department

#### Other calls for the month include:

## 414 Emergency Medical Service / Ambulance

- **1** SWAT Team medics requested to assist in Bloomington
- **1** Elevator Rescue
- **3 Hazardous Conditions** (Gas leaks, CO leaks, electrical arcing, etc.)
- **15 Service & Good Intent** (Smoke scares, possible hazards w/o hazard, unauthorized burning, etc.)

#### 39 False Fire Alarms

1 Malicious 19 Commercial 19 Residential